

Topic	#	1002 Accessible Units	#	1003 Type A Units	#	ADA-ABA-AG 809	#	1004 Type B Units	Reccomendation	Comments
General	1	1002.1 General. Accessible units shall comply with Section 1002.	1	1003.1 General. Type A units shall comply with Section 1003.		809.1 General. Residential dwelling units shall comply with 809. Residential dwelling units required to provide mobility features shall comply with 809.2 through 809.4. Residential dwelling units required to provide communication features shall comply with 809.5.	1	1004.1 General. Type B units shall comply with Section 1004.		
Primary Entrance	1	1002.2 Primary Entrance. The accessible primary entrance shall be on an accessible route from public and common areas. The primary entrance shall not be to a bedroom.	1	1003.2 Primary Entrance. The accessible primary entrance shall be on an accessible route from public and common areas. The primary entrance shall not be to a bedroom.		203. 8 Residential Facilities. In residential facilities, common use areas that do not serve residential dwelling units required to provide mobility features complying with 809. 2 through 809.4 shall not be required to comply with these requirements or to be on an accessible route.	1	1004.2 Primary Entrance. The accessible primary entrance shall be on an accessible route from public and common areas. The primary entrance shall not be to a bedroom.		Same
Accessible Route	1	1002.3 Accessible Route. Accessible routes within Accessible units shall comply with Section 1002.3. Exterior spaces less than 30 inches (760 mm) in depth or width shall comply with Sections 1002.3.1, 1002.3.3, 302, and 303.	1	1003.3 Accessible Route. Accessible routes within Type A units shall comply with section 1003.3. Exterior spaces less than 30 inches (760 mm) in depth or width shall comply with Sections 1003.3.1, 1003.3.3, 302, and 303.			1	1004.3 Accessible Route. Accessible routes within Type B units shall comply with Section 1004.		Why different requirements? Red text makes no sense. Is this really intended to be an exception from 1003.3.2?
						EXCEPTION: Turning space shall not be required in exterior spaces 30 inches (760 mm) maximum in depth or width.			Make Access & A exception like 809 and use 809 wording. Much cleaner.	
Accessible Route		302 Floor Surfaces		302 Floor Surfaces						Why different requirements?
Accessible Route		302.1 General. Floor surfaces shall be stable, firm and slip resistant, and shall comply with Section 302. Changes in level in floor surfaces shall comply with Section 303.		302.1 General. Floor surfaces shall be stable, firm and slip resistant, and shall comply with Section 302. Changes in level in floor surfaces shall comply with Section 303.						Why different requirements? Stable & Firm are subjective and not enforceable.
Accessible Route		302.2 Carpet. Carpet or carpet tile shall be securely attached and shall have a firm cushion , pad, or backing or no cushion or pad. Carpet or carpet tile shall have a level loop, textured loop, level cut pile, or level cut/uncut pile texture. The pile shall be 1/2 inch (13 mm) maximum in height. Exposed edges of carpet shall be fastened to the floor and shall have trim along the entire length of the exposed edge. Carpet edge trim shall comply with Section 303.		302.2 Carpet. Carpet or carpet tile shall be securely attached and shall have a firm cushion , pad, or backing or no cushion or pad. Carpet or carpet tile shall have a level loop, textured loop, level cut pile, or level cut/uncut pile texture. The pile shall be 1/2 inch (13 mm) maximum in height. Exposed edges of carpet shall be fastened to the floor and shall have trim along the entire length of the exposed edge. Carpet edge trim shall comply with Section 303.						Why different requirements? Is there any other kind of carpet? Why list descriptors? Needs better criteria.
Accessible Route		302.3 Openings. Openings in floor surfaces shall be of a size that does not permit the passage of a 1/2 inch (13 mm) diameter sphere. except as allowed in Sections 407.4.3, 408.4.3, 409.4.3, 410.4, and 805. 10. Elongated openings shall be placed so that the long dimension is perpendicular to the dominant direction of travel.		302.3 Openings. Openings in floor surfaces shall be of a size that does not permit the passage of a 1/2 inch (13 mm) diameter sphere. except as allowed in Sections 407.4.3, 408.4.3, 409.4.3, 410.4, and 805. 10. Elongated openings shall be placed so that the long dimension is perpendicular to the dominant direction of travel.						Why different requirements? Reword
Accessible Route		303 Changes in Level		303 Changes in Level						Why different requirements?
Topic		1002 Accessible Units		1003 Type A Units		ADA-ABA-AG 809		1004 Type B Units		Comments
Accessible Route		303.1 General. Changes in level in floor surfaces shall comply with Section 303.		303.1 General. Changes in level in floor surfaces shall comply with Section 303.						Why different requirements?
Accessible Route		303.2 Vertical. Changes in level of 1/4 inch (6.4 mm) maximum in height shall be permitted to be vertical.		303.2 Vertical. Changes in level of 1/4 inch (6.4 mm) maximum in height shall be permitted to be vertical.						Why different requirements?

Dark Shading=Same
 Light Shading=Referenced text
 Bold #'s are req. per heading

Accessible Route	303.3 Beveled. Changes in level greater than 1/4 inch (6.4 mm) in height and not more than 1/2 inch (13 mm) maximum in height shall be beveled with a slope not steeper than 1 :2.	303.3 Beveled. Changes in level greater than 1/4 inch (6.4 mm) in height and not more than 1/2 inch (13 mm) maximum in height shall be beveled with a slope not steeper than 1 :2.				Why different requirements?	
Accessible Route	303.4 Ramped. Changes in level greater than 1/2 inch (13 mm) in height shall be ramped and shall comply with Section 405 or 406.	303.4 Ramped. Changes in level greater than 1/2 inch (13 mm) in height shall be ramped and shall comply with Section 405 or 406.				Why different requirements?	
Accessible Route	2 1002.3.1 Location. At least one accessible route shall connect all spaces and elements that are a part of the unit. Where only one accessible route is provided, it shall not pass through bathrooms and toilet rooms, closets, or similar spaces.	2 1003.3.1 Location. At least one accessible route shall connect all spaces and elements that are a part of the unit. Where only one accessible route is provided, it shall not pass through bathrooms and toilet rooms, closets, or similar spaces.	809.2.1 Location. At least one accessible route shall connect all spaces and elements which are a part of the residential dwelling unit. Where only one accessible route is provided, it shall not pass through bathrooms, closets, or similar spaces.	2	1004.3.1 Location. At least one accessible route shall connect all spaces and elements that are a part of the unit. Where only one accessible route is provided, it shall not pass through bathrooms and toilet rooms, closets, or similar spaces.	Same	
Accessible Route	3 EXCEPTION: An accessible route is not required to unfinished attics and unfinished basements that are part of the unit.	3 EXCEPTION: An accessible route is not required to unfinished attics and unfinished basements that are part of the unit.	EXCEPTION: Accessible routes shall not be required to or within unfinished attics or unfinished basements.	2	EXCEPTION: One of the following is not required to be on an accessible route: 1. A raised floor area in a portion of a living, dining, or sleeping room; or 2. A sunken floor area in a portion of a living, dining, or sleeping room; or 3. A mezzanine that does not have plumbing fixtures or an enclosed habitable space.	Why different requirements?	
Accessible Route	4 1002.3.2 Turning Space. All rooms served by an accessible route shall provide a turning space complying with Section 304.	4 1003.3.2 Turning Space. All rooms served by an accessible route shall provide a turning space complying with Section 304.	809.2.2 Turning Space. All rooms served by an accessible route shall provide a turning space complying with 304.			Why different requirements?	
Accessible Route		5 EXCEPTION: Toilet rooms and bathrooms that are not required to comply with Section 1003.11.				Why different requirements?	Redundant/reword previous requirement
Accessible Route	304 Turning Space	304 Turning Space				Why different requirements?	
Accessible Route	304.1 General. A turning space shall comply with Section 304.A29	304.1 General. A turning space shall comply with Section 304.A29				Why different requirements?	
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809		1004 Type B Units	Comments	
Accessible Route	304.2 Floor Surface. Floor surfaces of a turning space shall have a slope not steeper than 1 :48 and shall comply with Section 302.	304.2 Floor Surface. Floor surfaces of a turning space shall have a slope not steeper than 1 :48 and shall comply with Section 302.				Why different requirements?	302 is redundant
Accessible Route	304.3 Size. Turning spaces shall comply with Section 304.3.1 or 304.3.2	304.3 Size. Turning spaces shall comply with Section 304.3.1 or 304.3.2				Why different requirements?	
Accessible Route	304. 2 T-Shaped Space. The turning space shall be a T-shaped space within a 60-inch (1525 mm) minimum square, with arms and base 36 inches (915 mm) minimum in width. Each arm of the T shall be clear of obstructions 12 inches (305 mm) minimum in each direction, and the base shall be clear of obstructions 24 inches (610 mm) minimum. The turning space shall be permitted to include knee and toe clearance complying with Section 306 only at the end of either the base or one arm.	304. 2 T-Shaped Space. The turning space shall be a T-shaped space within a 60-inch (1525 mm) minimum square, with arms and base 36 inches (915 mm) minimum in width. Each arm of the T shall be clear of obstructions 12 inches (305 mm) minimum in each direction, and the base shall be clear of obstructions 24 inches (610 mm) minimum. The turning space shall be permitted to include knee and toe clearance complying with Section 306 only at the end of either the base or one arm.				Why different requirements?	Cumbersome wording. Change the size of the "T" would be cleaner.
Accessible Route	304.3.1 Circular Space. The turning space shall be a circular space with a 60-inch (1525 mm) minimum diameter. The turning space shall be permitted to include knee and toe clearance complying with Section 306.	304.3.1 Circular Space. The turning space shall be a circular space with a 60-inch (1525 mm) minimum diameter. The turning space shall be permitted to include knee and toe clearance complying with Section 306.				Why different requirements?	Change definition to eliminate extra verbage

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Accessible Route	304.4 Door Swing. Unless otherwise specified doors shall be permitted to swing into turning spaces	304.4 Door Swing. Unless otherwise specified doors shall be permitted to swing into turning spaces					Why different requirements?	Is there a prohibition soemwhere? If not cut out the extra wording.
Accessible Route	5 1002.3.3 Components. Accessible routes shall consist of one or more of the following elements: walking surfaces with a slope not steeper than 1:20, ramps, elevators, and platform lifts.	6 1003.3.3 Components. Accessible routes shall consist of one or more of the following elements: walking surfaces with a slope not steeper than 1:20, ramps, elevators, and platform lifts.			4	1004.3.2 Components. Accessible routes shall consist of one or more of the following elements: walking surfaces with a slope not steeper than 1:20, doorways, ramps, elevators, and platform lifts.	Same except for one word	Specified in 402.2. Redundant.
Accessible Route	6 1002.4 Walking Surfaces. Walking surfaces that are part of an accessible route shall comply with Section 403.	7 1003.4 Walking Surfaces. Walking surfaces that are part of an accessible route shall comply with Section 403.			5	1004.4 Walking Surfaces. Walking surfaces that are part of an accessible route shall comply with Section 1004.4.	Why different requirements?	Redundant- see 402.2
Accessible Route					6	1004.4.1 Width. Clear width of an accessible route shall comply with Section 403.5.	Why different requirements?	Redundant- see 402.2
Accessible Route	403 Walking Surfaces	403 Walking Surfaces					Why different requirements?	
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809			1004 Type B Units	Comments	
Accessible Route	403.1 General. Walking surfaces that are a part of an accessible route shall comply with Section 403.	403.1 General. Walking surfaces that are a part of an accessible route shall comply with Section 403.					Why different requirements?	
Accessible Route	403.2 Floor Surface. Floor surfaces shall comply with Section 302.	403.2 Floor Surface. Floor surfaces shall comply with Section 302.					Why different requirements?	
Accessible Route	403.3 Slope. The running slope of walking surfaces shall not be steeper than 1:20. The cross slope of a walking surface shall not be steeper than 1:48.	403.3 Slope. The running slope of walking surfaces shall not be steeper than 1:20. The cross slope of a walking surface shall not be steeper than 1:48.					Why different requirements?	
Accessible Route	403.4 Changes in Level. Changes in level shall comply with Section 303.	403.4 Changes in Level. Changes in level shall comply with Section 303.					Why different requirements?	
Accessible Route	403.5 Clear Width. Clear width of an accessible route shall comply with Table 403.5.	403.5 Clear Width. Clear width of an accessible route shall comply with Table 403.5.					Why different requirements?	
Accessible Route	403.5.1 Clear Width at Turn. Where an accessible route makes a 180 degree turn around an object that is less than 48 inches (1220 mm) in width, clear widths shall be 42 inches (1065 mm) minimum approaching the turn, 48 inches (1220 mm) minimum during the turn, and 42 inches (1065 mm) minimum leaving the turn.	403.5.1 Clear Width at Turn. Where an accessible route makes a 180 degree turn around an object that is less than 48 inches (1220 mm) in width, clear widths shall be 42 inches (1065 mm) minimum approaching the turn, 48 inches (1220 mm) minimum during the turn, and 42 inches (1065 mm) minimum leaving the turn.					Why different requirements?	
Accessible Route	EXCEPTION: Section 403.5.1 shall not apply where the clear width at the turn is 60 inches (1525 mm) minimum.	EXCEPTION: Section 403.5.1 shall not apply where the clear width at the turn is 60 inches (1525 mm) minimum.					Why different requirements?	
Accessible Route	403.5.2 Passing Space. An accessible route with a clear width less than 60 inches (1525 mm) shall provide passing spaces at intervals of 200 feet (61 m) maximum. Passing spaces shall be either a 60 inch (1525 mm) minimum by 60 inch (1525 mm) minimum space, or an intersection of two walking surfaces that provide a T-shaped turning space complying with Section 304.3.2 provided the base and arms of the T-shaped space extend 48 inches (1220 mm) minimum beyond the intersection.	403.5.2 Passing Space. An accessible route with a clear width less than 60 inches (1525 mm) shall provide passing spaces at intervals of 200 feet (61 m) maximum. Passing spaces shall be either a 60 inch (1525 mm) minimum by 60 inch (1525 mm) minimum space, or an intersection of two walking surfaces that provide a T-shaped turning space complying with Section 304.3.2 provided the base and arms of the T-shaped space extend 48 inches (1220 mm) minimum beyond the intersection.					Why different requirements?	
Accessible Route	403.6 Handrails. Where handrails are required at the side of a corridor they shall comply with Sections 505.4 through 505.9.	403.6 Handrails. Where handrails are required at the side of a corridor they shall comply with Sections 505.4 through 505.9.					Why different requirements?	

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units	Comments	
Accessible Route				7 1004.2 Changes in Level. Changes in level shall comply with Section 303.	Why different requirements?	Redundant - 403.4
Accessible Route				8 EXCEPTION: Where exterior deck, patio or balcony surface materials are impervious the finished exterior impervious surface shall be 4 inches (100 mm) maximum below the floor level of the adjacent interior spaces of the unit.	Why different requirements?	Why is this a accessibility issue?
Accessible Route	7 1002.5 Doors and Doorways. The primary entrance door to the unit, and all other doorways intended for user passage, shall comply with Section 404.	8 1003.5 Doors and Doorways. The primary entrance door to the unit, and all other doorways intended for user passage, shall comply with Section 404.		9 1004.5 Doors and Doorways. Doors and doorways shall comply with Section 1004.5. 1004.5.1 Primary Entrance Door. The primary entrance door to the unit shall comply with Section 404.	Virtually the same, why different wording?	Redundant
Accessible Route	8 EXCEPTION: Existing doors to hospital patient sleeping rooms shall be exempt from the requirement for space at the latch side provided the door is 44 inches (1120 mm) minimum in width.	9 EXCEPTIONS: 1. Thresholds at exterior sliding doors shall be permitted to be 3/4 inch (19 mm) maximum in height, provided they are beveled with a slope not greater than 1:2. 2. In toilet rooms and bathrooms not required to comply with Section 1003.11, maneuvering clearances required by Section 404.2.3 are not required on the toilet room or bathroom side of the door.		10 EXCEPTION: Maneuvering clearances required by Section 404.2.3 shall not be required on the unit side of the primary entrance door.	Why different requirements?	
Accessible Route	404 Doors and Doorways	404 Doors and Doorways				
Accessible Route	404.1 General. Doors and doorways that are part of an accessible route shall comply with Section 404.	404.1 General. Doors and doorways that are part of an accessible route shall comply with Section 404.				
Accessible Route	404.2 Manual Doors. Manual doors and doorways and manual gates, including ticket gates, shall comply with the requirements of Section 404.2	404.2 Manual Doors. Manual doors and doorways and manual gates, including ticket gates, shall comply with the requirements of Section 404.2				
Accessible Route	EXCEPTION: Doors, doorways, and gates designed to be operated only by security personnel shall not be required to comply with Sections 404.2.6, 404.2.7, and 404.2.8.	EXCEPTION: Doors, doorways, and gates designed to be operated only by security personnel shall not be required to comply with Sections 404.2.6, 404.2.7, and 404.2.8.				
Accessible Route	404.2.1 Double-Leaf Doors and Gates. At least one of the active leaves of doorways with two leaves shall comply with Sections 404.2.2 and 404.2.3.	404.2.1 Double-Leaf Doors and Gates. At least one of the active leaves of doorways with two leaves shall comply with Sections 404.2.2 and 404.2.3.				
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units	Comments	
Accessible Route	404.2.2 Clear Width. Doorways shall have a clear opening width of 32 inches (815 mm) minimum. Clear opening width of doorways with swinging doors shall be measured between the face of door and stop, with the door open 90 degrees. Openings, doors and doorways without doors more than 24 inches (610 mm) in depth shall provide a clear opening width of 36 inches (915 mm) minimum. There shall be no projections into the clear opening width lower than 34 inches (865 mm) above the floor. Projections into the clear opening width between 34 inches (865 mm) and 80 inches (2030 mm) above the floor shall not exceed 4 inches (100 mm).	404.2.2 Clear Width. Doorways shall have a clear opening width of 32 inches (815 mm) minimum. Clear opening width of doorways with swinging doors shall be measured between the face of door and stop, with the door open 90 degrees. Openings, doors and doorways without doors more than 24 inches (610 mm) in depth shall provide a clear opening width of 36 inches (915 mm) minimum. There shall be no projections into the clear opening width lower than 34 inches (865 mm) above the floor. Projections into the clear opening width between 34 inches (865 mm) and 80 inches (2030 mm) above the floor shall not exceed 4 inches (100 mm).				

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Accessible Route	EXCEPTIONS: 1. Door closers and door stops shall be permitted to be 78 inches (1980 mm) minimum above the floor. 2. In alterations, a projection of 5/8 inch (16 mm) maximum into the required clear opening width shall be permitted for the latch side stop.	EXCEPTIONS: 1. Door closers and door stops shall be permitted to be 78 inches (1980 mm) minimum above the floor. 2. In alterations, a projection of 5/8 inch (16 mm) maximum into the required clear opening width shall be permitted for the latch side stop.						
Accessible Route	404.2.3 Maneuvering Clearances at Doors. Minimum maneuvering clearances at doors shall comply with Section 404.2.3 and shall include the full clear opening width of the doorway.	404.2.3 Maneuvering Clearances at Doors. Minimum maneuvering clearances at doors shall comply with Section 404.2.3 and shall include the full clear opening width of the doorway.						
Accessible Route	404.2.3.1 Swinging Doors. Swinging doors shall have maneuvering clearances complying with Table 404.2.3.1	404.2.3.1 Swinging Doors. Swinging doors shall have maneuvering clearances complying with Table 404.2.3.1						
Accessible Route	404.2.3.2 Sliding and Folding Doors. Sliding doors and folding doors shall have maneuvering clearances complying with Table 404.2.3.2.	404.2.3.2 Sliding and Folding Doors. Sliding doors and folding doors shall have maneuvering clearances complying with Table 404.2.3.2.						
Accessible Route	404.2.3.3 Doorways without Doors. Doorways without doors that are less than 36 inches (915 mm) in width shall have maneuvering clearances complying with Table 404.2.3.3.	404.2.3.3 Doorways without Doors. Doorways without doors that are less than 36 inches (915 mm) in width shall have maneuvering clearances complying with Table 404.2.3.3.						
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units			Comments	
Accessible Route	204.2.3.4 Recessed Doors. Where any obstruction within 18 inches (455 mm) of the latch side of a doorway projects more than 8 inches (205 mm) beyond the face of the door, measured perpendicular to the face of the door, maneuvering clearances for a forward approach shall be provided.	204.2.3.4 Recessed Doors. Where any obstruction within 18 inches (455 mm) of the latch side of a doorway projects more than 8 inches (205 mm) beyond the face of the door, measured perpendicular to the face of the door, maneuvering clearances for a forward approach shall be provided.						
Accessible Route	404.2.3.5 Floor Surface. Floor surface within the maneuvering clearances shall have a slope not steeper than 1 :48 and shall comply with Section 302.	404.2.3.5 Floor Surface. Floor surface within the maneuvering clearances shall have a slope not steeper than 1 :48 and shall comply with Section 302.						
Accessible Route	404.2.4 Thresholds at Doorways. If provided thresholds at doorways shall be 1/2 inch (13 mm) maximum in height. Raised thresholds and changes in level at doorways shall comply with Sections 302 and 303.	404.2.4 Thresholds at Doorways. If provided thresholds at doorways shall be 1/2 inch (13 mm) maximum in height. Raised thresholds and changes in level at doorways shall comply with Sections 302 and 303.						
Accessible Route	EXCEPTION: Section 404.2.4 shall not apply to existing thresholds or altered thresholds 3/4 inch (19 mm) maximum in height that have a beveled edge on each side with a maximum slope of 1:2 for the height exceeding 1/4 inch (6.4 mm).	EXCEPTION: Section 404.2.4 shall not apply to existing thresholds or altered thresholds 3/4 inch (19 mm) maximum in height that have a beveled edge on each side with a maximum slope of 1:2 for the height exceeding 1/4 inch (6.4 mm).						
Accessible Route	404.2.5 Two Doors in Series. Distance between two hinged or pivoted doors in series shall be 48 inches (1220 mm) minimum plus the width of any door swinging into the space. The space between the doors shall provide a turning space complying with Section 304.	404.2.5 Two Doors in Series. Distance between two hinged or pivoted doors in series shall be 48 inches (1220 mm) minimum plus the width of any door swinging into the space. The space between the doors shall provide a turning space complying with Section 304.						
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units			Comments	

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Accessible Route	404.2.6 Door Hardware. Handles, pulls latches, locks, and other operable parts on accessible doors shall have a shape that is easy to grasp with one hand and does not require tight grasping, pinching, or twisting of the wrist to operate. Operable parts of such hardware shall be 34 inches (865 mm) minimum and 48 inches (1220 mm) maximum above the floor. Where sliding doors are in the fully open position, operating hardware shall be exposed and usable from both sides.	404.2.6 Door Hardware. Handles, pulls latches, locks, and other operable parts on accessible doors shall have a shape that is easy to grasp with one hand and does not require tight grasping, pinching, or twisting of the wrist to operate. Operable parts of such hardware shall be 34 inches (865 mm) minimum and 48 inches (1220 mm) maximum above the floor. Where sliding doors are in the fully open position, operating hardware shall be exposed and usable from both sides.						
Accessible Route	EXCEPTION: Locks used only for security purposes and not used for normal operation are permitted in any location.	EXCEPTION: Locks used only for security purposes and not used for normal operation are permitted in any location.						
Accessible Route	404.2.7 Closing Speed.	404.2.7 Closing Speed.						
Accessible Route	404.2.7.1 Door Closers. Door closers shall be adjusted so that from an open position of 90 degrees, the time required to move the door to an open position of 12 degrees shall be 5 seconds minimum.	404.2.7.1 Door Closers. Door closers shall be adjusted so that from an open position of 90 degrees, the time required to move the door to an open position of 12 degrees shall be 5 seconds minimum.						
Accessible Route	404.2.7.2 Spring Hinges. Door spring hinges shall be adjusted so that from the open position of 70 degrees, the door shall move to the closed position in 1.5 seconds minimum.	404.2.7.2 Spring Hinges. Door spring hinges shall be adjusted so that from the open position of 70 degrees, the door shall move to the closed position in 1.5 seconds minimum.						
Accessible Route	404.2.8 Door-Opening Force. Fire doors shall have the minimum opening force allowable by the appropriate administrative authority. The force for pushing or pulling open doors other than fire doors shall be as follows: 1. Interior hinged door: 5.0 pounds (22.2 N) maximum 2. Sliding or folding door: 5.0 pounds (22.2 N) maximum These forces do not apply to the force required to retract latch bolts or disengage other devices that hold the door in a closed position.	404.2.8 Door-Opening Force. Fire doors shall have the minimum opening force allowable by the appropriate administrative authority. The force for pushing or pulling open doors other than fire doors shall be as follows: 1. Interior hinged door: 5.0 pounds (22.2 N) maximum 2. Sliding or folding door: 5.0 pounds (22.2 N) maximum These forces do not apply to the force required to retract latch bolts or disengage other devices that hold the door in a closed position.						
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units				Comments
Accessible Route	404.2.9 Door Surface. Door surfaces within 10 inches (255 mm) of the floor, measured vertically, shall be a smooth surface on the push side extending the full width of the door. Parts creating horizontal or vertical joints in such surface shall be within 1/16 inch (1.6 mm) of the same plane as the other. Cavities created by added kick plates shall be capped.	404.2.9 Door Surface. Door surfaces within 10 inches (255 mm) of the floor, measured vertically, shall be a smooth surface on the push side extending the full width of the door. Parts creating horizontal or vertical joints in such surface shall be within 1/16 inch (1.6 mm) of the same plane as the other. Cavities created by added kick plates shall be capped.						

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Accessible Route	EXCEPTIONS: 1. Sliding doors. 2. Tempered glass doors without stiles and having a bottom rail or shoe with the top leading edge tapered at no less than 60 degrees from the horizontal shall not be required to meet the 10 inch (255 mm) bottom rail height requirement. 3. Doors that do not extend to within 10 inches (255 mm) of the floor.	EXCEPTIONS: 1. Sliding doors. 2. Tempered glass doors without stiles and having a bottom rail or shoe with the top leading edge tapered at no less than 60 degrees from the horizontal shall not be required to meet the 10 inch (255 mm) bottom rail height requirement. 3. Doors that do not extend to within 10 inches (255 mm) of the floor.						
Accessible Route	404.2.10 Vision Lites. Doors and sidelites adjacent to doors containing one or more glazing panels that permit viewing through the panels shall have the bottom of at least one panel on either the door or an adjacent sidelite 43 inches (1090 mm) maximum above the floor.	404.2.10 Vision Lites. Doors and sidelites adjacent to doors containing one or more glazing panels that permit viewing through the panels shall have the bottom of at least one panel on either the door or an adjacent sidelite 43 inches (1090 mm) maximum above the floor.						
Accessible Route	EXCEPTION: Vision lites with the lowest part more than 66 inches (1675 mm) above the floor are not required to comply with Section 404.2.10.	EXCEPTION: Vision lites with the lowest part more than 66 inches (1675 mm) above the floor are not required to comply with Section 404.2.10.						
Accessible Route	404.3 Automatic Doors. Automatic doors and automatic gates shall comply with Section 404.3. Full powered automatic doors shall comply with ANSI/BHMA A156.10 listed in Section 105.2.4. Powerassist and low-energy doors shall comply with ANSI/BHMA A156.19 listed in Section 105.2.3.	404.3 Automatic Doors. Automatic doors and automatic gates shall comply with Section 404.3. Full powered automatic doors shall comply with ANSI/BHMA A156.10 listed in Section 105.2.4. Powerassist and low-energy doors shall comply with ANSI/BHMA A156.19 listed in Section 105.2.3.						
Accessible Route	EXCEPTION: Doors, doorways, and gates designed to be operated only by security personnel shall not be required to comply with Sections 404.3.2, 404.3.4, and 404.3.5.	EXCEPTION: Doors, doorways, and gates designed to be operated only by security personnel shall not be required to comply with Sections 404.3.2, 404.3.4, and 404.3.5.						
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units			Comments	
Accessible Route	404.3.1 Clear Opening Width. Doorways shall have a clear opening width of 32 inches (815 mm) in power-on and power-off mode. The minimum clear opening width for automatic door systems shall be based on the clear opening width provided with all leaves in the open position.	404.3.1 Clear Opening Width. Doorways shall have a clear opening width of 32 inches (815 mm) in power-on and power-off mode. The minimum clear opening width for automatic door systems shall be based on the clear opening width provided with all leaves in the open position.						
Accessible Route	404.3.2 Maneuvering Clearances. Maneuvering clearances at power-assisted doors shall comply with Section 404.2.3.	404.3.2 Maneuvering Clearances. Maneuvering clearances at power-assisted doors shall comply with Section 404.2.3.						
Accessible Route	404.3.3 Thresholds. Thresholds and changes in level at doorways shall comply with Section 404.2.4.	404.3.3 Thresholds. Thresholds and changes in level at doorways shall comply with Section 404.2.4.						
Accessible Route	404.3.4 Two Doors in Series. Doors in series shall comply with Section 404.2.5.	404.3.4 Two Doors in Series. Doors in series shall comply with Section 404.2.5.						
Accessible Route	404.3.5 Control Switches. Manually operated control switches shall comply with Section 309. The clear floor space adjacent to the control switch shall be located beyond the arc of the door swing.	404.3.5 Control Switches. Manually operated control switches shall comply with Section 309. The clear floor space adjacent to the control switch shall be located beyond the arc of the door swing.						

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Accessible Route					11	1004.5.2 User Passage Doorways. Doorways intended for user passage shall comply with Section 1004.5.2.		Why different requirements?	What is a "User Passage Door"? Redundant see 402.2
Accessible Route					12	1004.5.2.1 Clear Width. Doorways shall have a clear opening of 31 3/4 inches (810 mm) minimum. Clear opening of swinging doors shall be measured between the face of the door and stop, with the door open 90 degrees.		Why different requirements?	
Accessible Route					13	1004.5.2.2 Thresholds. Thresholds shall comply with Section 303.		Why different requirements?	
Accessible Route					14	EXCEPTION: Thresholds at exterior sliding doors shall be permitted to be 3/4 inch (19 mm) maximum in height, provided they are beveled with a slope not steeper than 1:2.		Why different requirements?	
Accessible Route					15	1004.5.2.3 Automatic Doors. Automatic doors shall comply with Section 404.3.		Why different requirements?	
Topic	1002 Accessible Units		1003 Type A Units		ADA-ABA-AG 809		1004 Type B Units		Comments
Accessible Route					16	1004.5.2.4 Double Leaf Doorways. Where an inactive leaf with operable parts higher than 48 inches (1220 mm) or lower than 15 inches (380 mm) above the floor is provided, the active leaf shall provide the clearance required by Section 1004.5.2.1		Why different requirements?	Redundant - See 404.2.2
Accessible Route	9	1002.6 Ramps. Ramps shall comply with Section 405.	10	1003.6 Ramps. Ramps shall comply with Section 405.	17	1004.6 Ramps. Ramps shall comply with Section 405.		Same	
Accessible Route	10	1002.7 Elevators. Elevators within the unit shall comply with Section 407, 408, or 409.	11	1003.7 Elevators. Elevators within the unit shall comply with Section 407, 408, or 409.	18	1004.7 Elevators. Elevators within the unit shall comply with Section 407, 408, or 409.		Same	
Accessible Route	11	1002.8 Platform Lifts. Platform lifts within the unit shall comply with Section 410.	12	1003.8 Platform Lifts. Platform lifts within the unit shall comply with Section 410.	19	1004.8 Platform Lifts. Platform lifts within the unit shall comply with Section 410.		Same	
Accessible Route	12	1002.9 Operable Parts. Lighting controls, electrical switches and receptacle outlets, environmental controls, appliance controls, operating hardware for operable windows, plumbing fixture controls, and user controls for security or intercom systems shall comply with Section 309.	13	1003.9 Operable Parts. Lighting controls, electrical switches and receptacle outlets, environmental controls, appliance controls, operating hardware for operable windows, plumbing fixture controls, and user controls for security or intercom systems shall comply with Section 309.	20	1004.9 Operable Parts. Lighting controls, electrical switches and receptacle outlets, environmental controls, and user controls for security or intercom systems shall comply with Sections 309.2 and 309.3.		Why different requirements?	Note that "B" units on require compliance with only 2 of the three technical sections of 309.
Accessible Route	13	EXCEPTIONS: 1. Receptacle outlets serving a dedicated use. 2. One receptacle outlet shall not be required to comply with Section 309 where all of the following conditions are met: (a) the receptacle outlet is above a length of countertop that is uninterrupted by a sink or appliance; (b) at least one receptacle outlet complying with Section 1002.9 is provided for that length of countertop; and (c) all other receptacle outlets provided for that length of countertop comply with Section 1002.9 3. Floor receptacle outlets. 4. HVAC diffusers. 5. Controls mounted on ceiling fans. 6. Where redundant controls other than light switches are provided for a single element one control in each space shall not be required to be accessible.	14	EXCEPTIONS: 1. Receptacle outlets serving a dedicated use. 2. One receptacle outlet is not required to comply with Section 309 where all of the following conditions are met: (a) the receptacle outlet is above a length of countertop that is uninterrupted by a sink or appliance; and (b) at least one receptacle outlet complying with Section 1003.9 is provided for that length of countertop; and (c) all other receptacle outlets provided for that length of countertop comply with Section 1003.9 3. Floor receptacle outlets. 4. HVAC diffusers. 5. Controls mounted on ceiling fans. 6. Where redundant controls other than light switches are provided for a single element one control in each space shall not be required to be accessible.	21	EXCEPTIONS: 1. Receptacle outlets serving a dedicated use. 2. One receptacle outlet is not required to comply with Sections 309.2 and 309.3 where all of the following conditions are met: (a) the receptacle outlet is above a length of countertop that is uninterrupted by a sink or appliance; and (b) at least one receptacle outlet complying with Section 1004.9 is provided for that length of countertop; and (c) all other receptacle outlets provided for that length of countertop comply with Section 1004.9. 3. Floor receptacle outlets. 4. HVAC diffusers. 5. Controls mounted on ceiling fans. 6. Controls or switches mounted on appliances. 7. Plumbing fixture controls.		Why different requirements?	
Topic	1002 Accessible Units		1003 Type A Units		ADA-ABA-AG 809		1004 Type B Units		Comments

Light Shading=Referenced text
Bold #'s are req. per heading

Accessible Route	309 Operable Parts	309 Operable Parts						
Accessible Route	309.1 General. Operable parts required to be accessible shall comply with Section 309.	309.1 General. Operable parts required to be accessible shall comply with Section 309.						
Accessible Route	309.2 Clear Floor Space. A clear floor space complying with Section 305 shall be provided.	309.2 Clear Floor Space. A clear floor space complying with Section 305 shall be provided.			309.2 Clear Floor Space. A clear floor space complying with Section 305 shall be provided.			
Accessible Route	309.3 Height. Operable parts shall be placed within one or more of the reach ranges specified in Section 308.	309.3 Height. Operable parts shall be placed within one or more of the reach ranges specified in Section 308.			309.3 Height. Operable parts shall be placed within one or more of the reach ranges specified in Section 308.			
Accessible Route	309.4 Operation. Operable parts shall be operable with one hand and shall not require tight grasping, pinching, or twisting of the wrist. The force required to activate operable parts shall be 5.0 pounds (22. N) maximum.	309.4 Operation. Operable parts shall be operable with one hand and shall not require tight grasping, pinching, or twisting of the wrist. The force required to activate operable parts shall be 5.0 pounds (22. N) maximum.						
Accessible Route	EXCEPTION: Gas pump nozzles shall not be required to provide operable parts that have an activating force of 5.0 pounds (22.2 N) maximum.	EXCEPTION: Gas pump nozzles shall not be required to provide operable parts that have an activating force of 5.0 pounds (22.2 N) maximum.						
Laundry Equipment	1 1002.10 Laundry Equipment. Washing machines and clothes dryers shall comply with Section 611.	1 1003.10 Laundry Equipment. Washing machines and clothes dryers shall comply with Section 611.		1	1004.10 Laundry Equipment. Washing machines and clothes dryers shall comply with Section 1004.10.		Why different requirements?	Not required by Fair Housing
Laundry Equipment				2	1004.10.1 Clear Floor Space. A clear floor space complying with Section 305.3, positioned for parallel approach, shall be provided. The clear floor space shall be centered on the appliance.		Why different requirements?	Why only the size and the parallel approach?
Laundry Equipment	611 Washing Machines and Clothes Dryers	611 Washing Machines and Clothes Dryers						
Laundry Equipment	611.1 General. Accessible washing machines and clothes dryers shall comply with Section 611.	611.1 General. Accessible washing machines and clothes dryers shall comply with Section 611.						
Laundry Equipment	611.2 Clear Floor Space. A clear floor space complying with Section 305, positioned for parallel approach, shall be provided. The clear floor space shall be centered on the appliance.	611.2 Clear Floor Space. A clear floor space complying with Section 305, positioned for parallel approach, shall be provided. The clear floor space shall be centered on the appliance.						
Laundry Equipment	611.3 Operable Parts. Operable parts, including doors, lint screens, detergent and bleach compartments, shall comply with Section 309.	611.3 Operable Parts. Operable parts, including doors, lint screens, detergent and bleach compartments, shall comply with Section 309.						
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809		1004 Type B Units		Comments	
Laundry Equipment	611.4 Height. Top loading machines shall have the door to the laundry compartment 36 inches (915 mm) maximum above the floor. Front loading machines shall have the bottom of the opening to the laundry compartment 15 inches (380 mm) minimum and 34 inches (865 mm) maximum above the floor.	611.4 Height. Top loading machines shall have the door to the laundry compartment 36 inches (915 mm) maximum above the floor. Front loading machines shall have the bottom of the opening to the laundry compartment 15 inches (380 mm) minimum and 34 inches (865 mm) maximum above the floor.						

Dark Shading=Same
 Light Shading=Referenced text
 Bold #'s are req. per heading

Toilet & Bathing Facilities	1	1002.11 Toilet and Bathing Facilities. Toilet and bathing facilities shall comply with Sections 603 through 610.	1	1003.11 Toilet and Bathing Facilities.	809.4 Toilet Facilities and Bathing Facilities. At least one toilet facility and bathing facility shall comply with 603 through 610. At least one of each type of fixture provided shall comply with applicable requirements of 603 through 610. Toilet and bathing fixtures required to comply with 603 through 610 shall be located in the same toilet and bathing area, such that travel between fixtures does not require travel between other parts of the residential dwelling unit.	1	1004.11 Toilet and Bathing Facilities. Toilet and bathing fixtures shall comply with Section 1004.11.		Why different requirements?				
Toilet & Bathing Facilities			2	1003.11.1 General. All toilet and bathing areas shall comply with Section 1003.11.9. At least one toilet and bathing facility shall comply with Section 1003.11. At least one lavatory, one water closet and either a bathtub or shower within the unit shall comply with Section 1003.11. The accessible toilet and bathing fixtures shall be in a single toilet/bathing area, such that travel between fixtures does not require travel through other parts of the unit.		2	EXCEPTION: Fixtures on levels not required to be accessible.		Why different requirements?	All must have showers???			
Toilet & Bathing Facilities						3	1004.11.1 Clear Floor Space. Clear floor space required by Section 1004.11.3.1 or 1004.11.3.2 shall comply with Sections 1004.11.1 and 305.3		Why different requirements?				
Toilet & Bathing Facilities			3	1003.11.2 Doors. Doors shall not swing into the clear floor space or clearance for any fixture.		4	1004.11.1.1 Doors. Doors shall not swing into the clear floor space for any fixture.		Why different requirements?				
Toilet & Bathing Facilities			4	EXCEPTION: Where a clear floor space complying with Section 305.3 is provided within the room beyond the arc of the door swing.		5	EXCEPTION: Where a clear floor space complying with Section 305.3, excluding knee and toe clearances under elements, is provided within the room beyond the arc of the door swing.		Why different requirements?	Exceptions redundant and not needed.			
Toilet & Bathing Facilities						6	1004.11.1.2 Knee and Toe Clearance. Clear floor space at fixtures shall be permitted to include knee and toe clearances complying with Section 306.		Why different requirements?				
Toilet & Bathing Facilities			5	1003.11.3 Overlap. Clear floor spaces, clearances at fixtures and turning spaces are permitted to overlap.		7	1004.11.1.3 Overlap. Clear floor spaces shall be permitted to overlap.		Why different requirements?	Redundant - see 603.2.2			
Topic		1002 Accessible Units		1003 Type A Units			ADA-ABA-AG 809			1004 Type B Units		Comments	
Toilet & Bathing Facilities			6	1003.11.4 Reinforcement. Reinforcement shall be provided for the future installation of grab bars and shower seats at water closets, bathtubs, and shower compartments. Where walls are located to permit the installation of grab bars and seats complying with Sections 604.5, 607.4, 608.3 and 608.4, reinforcement shall be provided for the future installation of grab bars and seats meeting those requirements.		8	1004.11.2 Reinforcement. Reinforcement shall be provided for the future installation of grab bars and shower seats at water closets, bathtubs, and shower compartments. Where walls are located to permit the installation of grab bars and seats complying with Sections 604.5, 607.4, 608.3 and 608.4, reinforcement shall be provided for the future installation of grab bars and seats meeting those requirements.		Why different requirements?				
Toilet & Bathing Facilities			7	EXCEPTION: Reinforcement is not required in a room containing only a lavatory and a water closet, provided the room does not contain the only lavatory or water closet on the accessible level of the dwelling unit.		9	EXCEPTION: Reinforcement is not required in a room containing only a lavatory and a water closet, provided the room does not contain the only lavatory or water closet on the accessible level of the unit.		Why different requirements?				

Dark Shading=Same
 Light Shading=Referenced text
 Bold #'s are req. per heading

Toilet & Bathing Facilities					10	1004.11.3 Toilet and Bathing Rooms. Either all toilet and bathing rooms provided shall comply with Section 1004.11.3.1 (Option A), or one toilet and bathing room shall comply with Section 1004.11.3.2 (Option B).		Why different requirements?	
Toilet & Bathing - Option "A"					11	1004.11.3.1 Option A. Each fixture provided shall comply with Section 1004.11.3.1.		Why different requirements?	
Toilet & Bathing - Option "A"					12	EXCEPTION: A lavatory and a water closet in a room containing only a lavatory and water closet, provided the room does not contain the only lavatory or water closet on the accessible level of the unit.		Why different requirements?	
Toilet & Bathing - Option "A"	2	1002.11.1 Vanity Counter Top Space. If vanity counter top space is provided in non-accessible dwelling or sleeping units within the same facility, equivalent vanity counter top space, in terms of size and proximity to the lavatory, shall also be provided in Accessible units.	8	1003.11.5 Lavatory. Lavatories shall comply with Section 606.		13	1004.11.3.1.1 Lavatory. A clear floor space complying with Section 305.3, positioned for a parallel approach, shall be provided. The clear floor space shall be centered on the lavatory.	Why different requirements?	
Toilet & Bathing - Option "A"			9	EXCEPTION: Cabinetry shall be permitted under the lavatory, provided: (a) the cabinetry can be removed without removal or replacement of the lavatory; (b) the floor finish extends under such cabinetry; and (c) the walls behind and surrounding cabinetry are finished.		14	EXCEPTIONS: 1. A lavatory complying with Section 606. 2. Cabinetry shall be permitted under the lavatory provided such cabinetry can be removed without removal or replacement of the lavatory, and the floor finish extends under such cabinetry.	Why different requirements?	
Topic	1002 Accessible Units		1003 Type A Units		ADA-ABA-AG 809		1004 Type B Units	Comments	
Toilet & Bathing - Option "A"			10	1003.11.6 Mirrors. Mirrors above lavatories shall have the bottom edge of the reflecting surface 40 inches (1015 mm) maximum above the floor.				Why different requirements?	
Toilet & Bathing - Option "A"			11	1003.11.7 Water Closet. Water closets shall comply with Section 1003.11.7.		15	1004.11.3.1.2 Water Closet. The lateral distance from the centerline of the water closet to a bathtub or lavatory shall be 18 inches (455 mm) minimum on the side opposite the direction of approach and 15 inches (380 mm) minimum on the other side. The lateral distance from the centerline of the water closet to an adjacent wall shall be 18 inches (455 mm). The lateral distance from the centerline of the water closet to a lavatory or bathtub shall be 15 inches (380 mm) minimum. The water closet shall be positioned to allow for future installation of a grab bar on the side with 18 inches (455 mm) clearance. Clearance around the water closet shall comply with Section 1004.11.3.1.2.1, 1004.11.3.1.2.2, or 1004.11.3.1.2.3.	Why different requirements?	
Toilet & Bathing - Option "A"						16	1004.11.3.1.2.1 Parallel Approach. A clearance 56 inches (1420 mm) minimum measured from the wall behind the water closet, and 48 inches (1220 mm) minimum measured from a point 18 inches (455 mm) from the centerline of the water closet on the side designated for future installation of grab bars shall be provided. Vanities or lavatories on the wall behind the water closet are permitted to overlap the clearance.	Why different requirements?	

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units	Comments
Toilet & Bathing - Option "A"				17 1004.11.3.1.2.2 Forward Approach. A clearance 66 inches (1675 mm) minimum measured from the wall behind the water closet, and 48 inches (1220 mm) minimum measured from a point 18 inches (455 mm) from the centerline of the water closet on the side designated for future installation of grab bars shall be provided. Vanities or lavatories on the wall behind the water closet are permitted to overlap the clearance.	Why different requirements?
Toilet & Bathing - Option "A"	12	1003.11.7.1 Location. The water closet shall be positioned with a wall to the rear and to one side. The centerline of the water closet shall be 16 inches (405 mm) minimum and 18 inches (455 mm) maximum from the sidewall.			Why different requirements?
Toilet & Bathing - Option "A"	13	1003.11.7.2 Clearance. A clearance around the water closet of 60 inches (1525 mm) minimum, measured perpendicular from the side wall, and 56 inches (1420 mm) minimum, measured perpendicular from the rear wall, shall be provided.			Why different requirements?
Toilet & Bathing - Option "A"	14	1003.11.7.3 Overlap. The required clearance around the water closet shall be permitted to overlap the water closet, associated grab bars, paper dispensers, coat hooks, shelves, accessible routes, clear floor space required at other fixtures, and the wheelchair turning space. No other fixtures or obstructions shall be located within the required water closet clearance.			Why different requirements?
Toilet & Bathing - Option "A"	15	EXCEPTION: A lavatory complying with Section 1003.11.5 shall be permitted on the rear wall 18 inches (455 mm) minimum from the centerline of the water closet where the clearance at the water closet is 66 inches (1675 mm) minimum measured perpendicular from the rear wall			Why different requirements?
Toilet & Bathing - Option "A"	16	1003.11.7.4 Height. The top of the water closet seat shall be 15 inches (380 mm) minimum and 19 inches (485 mm) maximum above the floor, measured to the top of the seat.			Why different requirements?
Toilet & Bathing - Option "A"	17	1003.11.7.5 Flush Controls. Hand operated flush controls shall comply with Section 1003.9. Flush controls shall be located on the open side of the water closet.			Why different requirements?
Toilet & Bathing - Option "A"	18	1003.11.8 Bathtub. Bathtubs shall comply with Section 607.		18 1004.11.3.1.3 Bathing Facilities. Where a bathtub or shower compartment is provided it shall conform with Section 1004.11.3.1.3.1, 1004.11.3.1.3.2, or 1004.11.3.1.3.3.	Why different requirements?
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units	Comments

Dark Shading=Same
 Light Shading=Referenced text
 Bold #'s are req. per heading

Toilet & Bathing - Option "A"					19	1004.11.3.1.3.1 Parallel Approach Bathtubs. A clearance 60 inches (1525 mm) minimum in length and 30 inches (760 mm) minimum in width shall be provided in front of bathtubs with a parallel approach. Lavatories complying with Section 606 shall be permitted in the clearance. A lavatory complying with Section 1004.11.3.1.1 shall be permitted at the control end of the bathtub if a clearance inches (1220 mm) minimum in length and 30 inches (760 mm) minimum in width for a parallel approach is provided in front of the bathtub.		Why different requirements?		
Toilet & Bathing - Option "A"					20	1004.11.3.1.3.2 Forward Approach Bathtubs. A clearance 60 inches (1525 mm) minimum in length and 48 inches (1220 mm) minimum in width shall be provided in front of bathtubs with a forward approach. A water closet shall be permitted in the clearance at the control end of the bathtub.		Why different requirements?		
Toilet & Bathing - Option "A"			19	EXCEPTIONS: 1. The removable in-tub seat required by Section 607.3 is not required. 2. Counter tops and cabinetry shall be permitted at the control end of the clearance, provided such counter tops and cabinetry can be removed and the floor finish extends under such cabinetry.				Why different requirements?		
Toilet & Bathing - Option "A"			20	1003.11.9 Shower. Showers shall comply with Section 608.		21	1004.11.3.1.3.3 Shower Compartment. If a shower compartment is the only bathing facility, the shower compartment shall have dimensions of 36 inches (915 mm) minimum in width and 36 inches (915 mm) minimum in depth. A clearance of 48 inches (1220 mm) minimum in length, measured perpendicular from the shower head wall and 30 inches (760 mm) minimum in depth, measured from the face of the shower compartment, shall be provided. Reinforcing for a shower seat is not required in shower compartments larger than 36 inches (915 mm) in width and 36 inches (915 mm) in depth.		Why different requirements?	
Topic	1002 Accessible Units		1003 Type A Units		ADA-ABA-AG 809	1004 Type B Units		Comments		
Toilet & Bathing - Option "A"			21	EXCEPTION: Counter tops and cabinetry shall be permitted at the control end of the clearance, provided such counter tops and cabinetry can be removed and the floor finish extends under such cabinetry.				Why different requirements?		
Toilet & Bathing - Option "B"						22	1004.11.3.2 Option B. One of each type of fixture provided shall comply with Section 1004.11.3.2. The accessible fixtures shall be in a single toilet/bathing area, such that travel between fixtures does not require travel through other parts of the unit.	Why different requirements?		
Toilet & Bathing - Option "B"						23	1004.11.3.2.1 Lavatory. Lavatories shall comply with Section 1004.11.3.2.1	Why different requirements?		

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Toilet & Bathing - Option "B"						24	1004.11.3.2.1.1 Clear Floor Space. A clear floor space complying with Section 305.3, positioned for a parallel approach, shall be provided.		Why different requirements?
Toilet & Bathing - Option "B"						25	EXCEPTIONS: 1. A lavatory complying with Section 606. 2. Cabinetry shall be permitted under the lavatory, provided such cabinetry can be removed without removal or replacement of the lavatory, and the floor finish extends under such cabinetry.		Why different requirements?
Toilet & Bathing - Option "B"						26	1004.11.3.2.1.2 Position. The clear floor space shall be centered on the lavatory.		Why different requirements?
Toilet & Bathing - Option "B"						27	1004.11.3.2.1.3 Height. The front of the lavatory shall be 34 inches (865 mm) maximum above the floor, measured to the higher of the fixture rim or counter surface.		Why different requirements?
Toilet & Bathing - Option "B"						28	1004.11.3.2.2 Water Closet. The water closet shall comply with Section 1004.11.3.1.2		Why different requirements?
Toilet & Bathing - Option "B"						29	1004.11.3.2.1 Bathing Facilities. Where either a bathtub or shower compartment is provided, it shall conform with Section 1004.11.3.2.3.1 or 1004.11.3.2.3.2		Why different requirements?
Topic	1002 Accessible Units	1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units					Comments
Toilet & Bathing - Option "B"						30	1004.11.3.2.3.1 Bathtub. A clearance 48 inches (1220 mm) minimum in length measured perpendicular from the control end of the bathtub, and 30 inches (760 mm) minimum in width shall be provided in front of bathtubs.		Why different requirements?
Toilet & Bathing - Option "B"						31	1004.11.3.2.3. 2 Shower Compartment. A shower compartment shall comply with Section 1004.11.3.1.3.3.		Why different requirements?
Kitchens	1 1002.12 Kitchens. Kitchens shall comply with Section 804. At least one work surface, 30 inches (760 mm) minimum in length, shall comply with Section 902.	1 1003.12 Kitchens. Kitchens shall comply with Section 1003.12.		809.3 Kitchen. Where a kitchen is provided, it shall comply with 804.		1	1004.12 Kitchens. Kitchens shall comply with Section 1004.12.		Why different requirements?
Kitchens	2 804.2 Clearance. Where a pass-through kitchen is provided, clearances shall comply with Section 804.2.1. Where a U-shaped kitchen is provided, clearances shall comply with Section 804.2.2.	2 1003.12.1 Clearance. Clearance complying with Section 1003.12.1 shall be provided.		804.2 Clearance. Where a pass through kitchen is provided, clearances shall comply with 804.2.1. Where a U-shaped kitchen is provided, clearances shall comply with 804.2.2.		2	1004.12.1 Clearance. Clearance complying with Section 1004.12.1 shall be provided.		Why different requirements?
Kitchens	EXCEPTION: Spaces that do not provide a cooktop or conventional range shall not be required to comply with Section 804.2.			EXCEPTION: Spaces that do not provide a cooktop or conventional range shall not be required to comply with 804.2.					
Kitchens	3 804.2.1 Pass Through Kitchen. In pass through kitchens where counters, appliances or cabinets are on two opposing sides, or where counters, appliances or cabinets are opposite a parallel wall, clearance between all opposing base cabinets, counter tops, appliances, or walls within kitchen work areas shall be 40 inches (1015 mm) minimum. Pass through kitchens shall have two entries.	3 1003.12.1.1 Minimum Clearance. Clearance between all opposing base cabinets, counter tops, appliances, or walls within kitchen work areas shall be 40 inches (1015 mm) minimum.		804.2.1 Pass Through Kitchen. In pass through kitchens where counters, appliances or cabinets are on two opposing sides, or where counters, appliances or cabinets are opposite a parallel wall, clearance between all opposing base cabinets, counter tops, appliances, or walls within kitchen work areas shall be 40 inches (1015 mm) minimum. Pass through kitchens shall have two entries.		3	1004.12.1.1 Minimum Clearance. Clearance between all opposing base cabinets, counter tops, appliances or walls within kitchen work areas shall be 40 inches (1015 mm) minimum.		Why different requirements?

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Kitchens	804.2.2 U-Shaped. In U-shaped kitchens enclosed on three contiguous sides, clearance between all opposing base cabinets, counter tops, appliances, or walls within kitchen work areas shall be 60 inches (1525 mm) minimum.	4	1003.12.1.2 U-Shaped Kitchens. In kitchens with counters, appliances, or cabinets on three contiguous sides, clearance between all opposing base cabinets, countertops, appliances, or walls within kitchen work areas shall be 60 inches (1525 mm) minimum.	804.2.2 U-Shaped. In U-shaped kitchens enclosed on three contiguous sides, clearance between all opposing base cabinets, counter tops, appliances, or walls within kitchen work areas shall be 60 inches (1525 mm) minimum.	4	1004.12.1.2 U-Shaped Kitchens. In kitchens with counters, appliances, or cabinets on three contiguous sides, clearance between all opposing base cabinets, countertops, appliances or walls within kitchen work areas shall be 60 inches (1525 mm) minimum.		Why different requirements?	
Kitchens		5	1003.12.2 Clear Floor Space. Clear floor spaces required by Sections 1003.12.3 through 1003.12.6 shall comply with Section 305.		5	1004.12.2 Clear Floor Space. Clear floor space at appliances shall comply with Sections 1004.12.2 and 305.3.		Why different requirements?	
Kitchens		6	1003.12.3 Work Surface. At least one section of counter shall provide a work surface 30 inches (760 mm) minimum in length complying with Section 1003.12.	804.3 Kitchen Work Surface. In residential dwelling units required to comply with 809, at least one 30 inches (760 mm) wide minimum section of counter shall provide a kitchen work surface that complies with 804.3.				Why different requirements?	
Kitchens	804.3 Work Surface. Work surfaces shall comply with Section 902.	7	1003.12.3.1 Clear Floor Space. A clear floor space, positioned for a forward approach to the work surface, shall be provided. Knee and toe clearance complying with Section 306 shall be provided. The clear floor space shall be centered on the work surface.	804.3.1 Clear Floor or Ground Space. A clear floor space complying with 305 positioned for a forward approach shall be provided. The clear floor or ground space shall be centered on the kitchen work surface and shall provide knee and toe clearance complying with 306.				Why different requirements?	
Kitchens	EXCEPTION: Spaces that do not provide a cooktop or conventional range shall not be required to provide an accessible work surface.								
Topic	1002 Accessible Units		1003 Type A Units	ADA-ABA-AG 809		1004 Type B Units		Comments	
Kitchens		8	EXCEPTION: Cabinetry shall be permitted under the work surface, provided: (a) the cabinetry can be removed without removal or replacement of the work surface (b) the floor finish extends under such cabinetry, and (c) the walls behind and surrounding cabinetry are finished.	EXCEPTION: Cabinetry shall be permitted under the kitchen work surface provided that all of the following conditions are met: (a) the cabinetry can be removed without removal or replacement of the kitchen work surface; (b) the finish floor extends under the cabinetry; and (c) the walls behind and surrounding the cabinetry are finished.				Why different requirements?	
Kitchens	ANSI 902.3 Height. The tops of dining surfaces and work surfaces shall be 28 inches (710 mm) minimum and 34 inches (865 mm) maximum in height above the floor.	9	1003.12.3.2 Height. The work surface shall be 34 inches (865 mm) maximum above the floor.	804.3.2 Height. The kitchen work surface shall be 34 inches (865 mm) maximum above the finish floor or ground.				Why different requirements?	
Kitchens		10	EXCEPTION: A counter that is adjustable to provide a work surface at variable heights 29 inches (735 mm) minimum and 36 inches (915 mm) maximum above the floor, or that can be relocated within that range without cutting the counter or damaging adjacent cabinets walls, doors, and structural elements, shall be permitted.	EXCEPTION: A counter that is adjustable to provide a kitchen work surface at variable heights, 29 inches (735 mm) minimum and 36 inches (915 mm) maximum, shall be permitted.				Why different requirements?	
Kitchens		11	1003.12.3.3 Exposed Surfaces. There shall be no sharp or abrasive surfaces under the exposed portions of work surface counters.	804.3.3 Exposed Surfaces. There shall be no sharp or abrasive surfaces under the work surface counters.				Why different requirements?	
Kitchens	804.4 Sinks. Sinks shall comply with Section 606.	12	1003.12.4 Sink. Sinks shall comply with Section 1003.12.4.	804.4 Sinks. Sinks shall comply with 606.	6	1004.12.2.1 Sink. A clear floor space, positioned for a parallel approach to the sink, shall be provided. The clear floor space shall be centered on the sink bowl.		Why different requirements?	CFS complying with what?

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Kitchens					7	EXCEPTION: Sinks complying with Section 606 shall be permitted to have a clear floor space positioned for a parallel or forward approach.		Why different requirements?	
Kitchens	606.2 Clear Floor Space. A clear floor space complying with Section 305.3, positioned for forward approach, shall be provided. Knee and toe clearance complying with Section 306 shall be provided. The dip of the overflow shall not be considered in determining knee and toe clearances.	13	1003.12.4.1 Clear Floor Space. A clear floor space, positioned for a forward approach to the sink, shall be provided. Knee and toe clearance complying with Section 306 shall be provided. The clear floor space shall be centered on the sink bowl.					Why different requirements?	
Topic	1002 Accessible Units		1003 Type A Units		ADA-ABA-AG 809		1004 Type B Units	Comments	
Kitchens	EXCEPTIONS: 1. A parallel approach complying with Section 305 shall be permitted to a kitchen sink in a space where a cook top or conventional range is not provided. 2. The requirement for knee and toe clearance shall not apply to a lavatory in a toilet and bathing facility for a single occupant, accessed only through a private office and not for common use or public use. 3. A knee clearance of 24 inches (610 mm) minimum above the floor shall be permitted at lavatories and sinks used primarily by children ages 6 through 12 where the rim or counter surface is 31 inches (785 mm) maximum above the floor. 4. A parallel approach complying with Section 305 shall be permitted at lavatories and sinks used primarily by children ages 5 and younger. 5. The requirement for knee and toe clearance shall not apply to more than one bowl of a multi-bowl sink. 6. A parallel	14	EXCEPTIONS: 1. The requirement for knee and toe clearance shall not apply to more than one bowl of a multi-bowl sink. 2. Cabinetry shall be permitted to be added under the sink, provided: (a) the cabinetry can be removed without removal or replacement of the sink, (b) the floor finish extends under such cabinetry, and (c) the walls behind and surrounding cabinetry are finished.					Why different requirements?	
Kitchens	606.3 Height. The front of lavatories and sinks shall be 34 inches (865 mm) maximum above the floor, measured to the higher of the rim or counter surface.	15	1003.12.4.2 Height. The front of the sink shall be 34 inches (865 mm) maximum above the floor, measured to the higher of the rim or counter surface.					Why different requirements?	
Kitchens		16	EXCEPTION: A sink and counter that is adjustable to variable heights 29 inches (735 mm) minimum and 36 inches (915 mm) maximum above the floor, or that can be relocated within that range without cutting the counter or damaging adjacent cabinets, walls, doors and structural elements, provided rough plumbing permits connections of supply and drain pipes for sinks mounted at the height of 29 inches (735 mm), shall be permitted.					Why different requirements?	
Kitchens	606.4 Faucets. Faucets shall comply with Section 309. Hand-operated metering faucets shall remain open for 10 seconds minimum.	17	1003.12.4.3 Faucets. Faucets shall comply with Section 309.					Why different requirements?	
Kitchens	EXCEPTION: A lavatory in a toilet and bathing facility for a single occupant, accessed only through a private office and not for common use or public use, shall not be required to comply with Section 606.								

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Kitchens	606.5 Lavatories with Enhanced Reach Range. Where enhanced reach range is required at lavatories, faucets and soap dispenser controls shall have a reach depth of 11 inches (280 mm) maximum or if automatic, shall be activated within a reach depth of 11 inches (280 mm) maximum. Water and soap flow shall be provided with a reach depth of 11 inches (280 mm) maximum.							
Kitchens	EXCEPTION: In Type A and Type B units, reach range for lavatory faucets and soap dispensers is not required.							
Kitchens	606.6 Exposed Pipes and Surfaces. Water supply and drainpipes under lavatories and sinks shall be insulated or otherwise configured to protect against contact. There shall be no sharp or abrasive surfaces under lavatories and sinks.	18	1003.12.4.4 Exposed Pipes and Surfaces. Water supply and drain pipes under sinks shall be insulated or otherwise configured to protect against contact. There shall be no sharp or abrasive surfaces under sinks					Why different requirements?
Kitchens		19	1003.12.5 Kitchen Storage. A clear floor space, positioned for a parallel or forward approach to the kitchen cabinets, shall be provided.					Why different requirements?
Kitchens		20	1003.12.6 Appliances. Where provided, kitchen appliances shall comply with Section 1003.12.6.	804.6 Appliances. Where provided, kitchen appliances shall comply with 804.6.				Why different requirements?
Kitchens	606.7 Operable Parts. Operable parts on towel dispensers and hand dryers shall comply with Table 606.7	21	1003.12.6.1 Operable Parts. All appliance controls shall comply with Section 1003.9	804.6.2 Operable Parts. All appliance controls shall comply with 309.				Why different requirements?
	Max. Reach .5" 2" 5" 6" 9" 11" Max. Height 48" 46" 42" 40" 36" 34"							
Topic	1002 Accessible Units		1003 Type A Units	ADA-ABA-AG 809	1004 Type B Units			Comments
Kitchens		22	EXCEPTIONS: 1. Appliance doors and door latching devices shall not be required to comply with Section 309. 2. Bottom-hinged appliance doors when in the open position, shall not be required to comply with Section 309.	EXCEPTIONS: 1. Appliance doors and door latching devices shall not be required to comply with 309.4. 2. Bottom-hinged appliance doors, when in the open position, shall not be required to comply with 309.3.				Why different requirements?
Kitchens		23	1003.12.6.2 Clear Floor Space. A clear floor space, positioned for a parallel or forward approach, shall be provided at each kitchen appliance. Clear floor spaces shall be permitted to overlap.	804.6.1 Clear Floor or Ground Space. A clear floor or ground space complying with 305 shall be provided at each kitchen appliance. Clear floor or ground spaces shall be permitted to overlap.				Why different requirements?
Kitchens		24	1003.12.6.3 Dishwasher. A clear floor space, positioned adjacent to the dishwasher door, shall be provided. The dishwasher door in the open position shall not obstruct the clear floor space for the dishwasher or an adjacent sink.	804.6.3 Dishwasher. Clear floor or ground space shall be positioned adjacent to the dishwasher door. The dishwasher door, in the open position, shall not obstruct the clear floor or ground space for the dishwasher or the sink.	8	1004.12.2.2 Dishwasher. A clear floor space, positioned for a parallel or forward approach to the dishwasher, shall be provided. The clear floor space shall be positioned beyond the swing of the dishwasher door.		Why different requirements?

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

Kitchens			25	1003.12.6.4 Range or Cooktop. A clear floor space, positioned for a parallel or forward approach to the space for a range or cooktop, shall be provided. Where the clear floor space is positioned for a forward approach, knee and toe clearance complying with Section 306 shall be provided. Where knee and toe space is provided, the underside of the range or cooktop shall be insulated or otherwise configured to protect from burns, abrasions, or electrical shock. The location of controls shall not require reaching across burners.	804.6.4 Range or Cooktop. Where a forward approach is provided, the clear floor or ground space shall provide knee and toe clearance complying with 306. Where knee and toe space is provided, the underside of the range or cooktop shall be insulated or otherwise configured to prevent burns, abrasions, or electrical shock. The location of controls shall not require reaching across burners.	9	1004.12.2.3 Cooktop. A clear floor space positioned for a parallel or forward approach to the cooktop, shall be provided. The centerline of the clear floor space shall align with the centerline of the cooktop. Where the clear floor space is positioned for a forward approach, knee and toe clearance complying with Section 306 shall be provided. Where knee and toe space is provided, the underside of the range or cooktop shall be insulated or otherwise configured to prevent burns, abrasions, or electrical shock.		Why different requirements?	
Kitchens			26	1003.12.6.5 Oven. Ovens shall comply with Section 1003.12.5. Ovens shall have controls on front panels, on either side of the door.	804.6.5 Oven. Ovens shall comply with 804.6.5.	10	1004.12.2.4 Oven. A clear floor space positioned for a parallel or forward approach to the oven, shall be provided.		Why different requirements?	
					804.6.5.3 Controls. Ovens shall have controls on front panels.					
Kitchens			27	1003.12.6.5.1 Side-Hinged Door Ovens. Side-hinged door ovens shall have a countertop positioned adjacent to the latch side of the oven door.	804.6.5.1 Side-Hinged Door Ovens. Side-hinged door ovens shall have the work surface required by 804.3 positioned adjacent to the latch side of the oven door.				Why different requirements?	
Kitchens			28	1003.12.6.5.2 Bottom-Hinged Door Ovens. Bottom-hinged door ovens shall have a countertop positioned adjacent to one side of the door.	804.6.5.2 Bottom-Hinged Door Ovens. Bottom-hinged door ovens shall have the work surface required by 804.3 positioned adjacent to one side of the door.				Why different requirements?	
Topic	1002 Accessible Units			1003 Type A Units	ADA-ABA-AG 809		1004 Type B Units		Comments	
Kitchens			29	1003.12.6.6 Refrigerator/Freezer. Combination refrigerators and freezers shall have at least 50 percent of the freezer compartment shelves, including the bottom of the freezer 54 inches (1370 mm) maximum above the floor when the shelves are installed at the maximum heights possible in the compartment. A clear floor space, positioned for a parallel approach to the space dedicated to a refrigerator/freezer shall be provided. The centerline of the clear floor space shall be offset 24 inches (610 mm) maximum from the centerline of the dedicated space.	804.6.6 Refrigerator/Freezer. Combination refrigerators and freezers shall have at least 50 percent of the freezer space 54 inches (1370 mm) maximum above the finish floor or ground. The clear floor or ground space shall be positioned for a parallel approach to the space dedicated to a refrigerator/freezer with the centerline of the clear floor or ground space offset 24 inches (610 mm) maximum from the centerline of the dedicated space.	11	1004.12.2.5 Refrigerator/Freezer. A clear floor space, positioned for a parallel or forward approach to the refrigerator/freezer shall be provided.		Why different requirements?	
Kitchens			30	1003.12.6.7 Trash Compactor. A clear floor space, positioned for a parallel or forward approach to the trash compactor shall be provided.		12	1004.12.2.6 Trash Compactor. A clear floor space, positioned for a parallel or forward approach to the trash compactor shall be provided.		Why different requirements?	
Windows	1	1002.13 Windows. Where operable windows are provided, at least one window in each sleeping, living, or dining space shall have operable parts complying with Section 1002.9. Each required operable window shall have operable parts complying with Section 1002.9.	1	1003.13 Windows. Where operable windows are provided, at least one window in each sleeping, living, or dining space shall have operable parts complying with Section 1003.9. Each required operable window shall have operable parts complying with Section 1003.	229.1 General. Where glazed openings are provided in accessible rooms or spaces for operation by occupants, at least one opening shall comply with 309. Each glazed opening required by an administrative authority to be operable shall comply with 309.	0			Why different requirements?	

Dark Shading=Same
 Light Shading=Referenced text
 Bold #'s are req. per heading

Windows				EXCEPTION: 1. Glazed openings in residential dwelling units required to comply with 809 shall not be required to comply with 229. 2. Glazed openings in guest rooms required to provide communication features and in guest rooms required to comply with 206.5.3 shall not be required to comply with 229.					
Storage Facilities	1	1002.14 Storage Facilities. Where storage facilities are provided, they shall comply with Section 905. Kitchen cabinets shall comply with Section 804.5.	1	1003.14 Storage Facilities. Where storage facilities are provided, they shall comply with Section 1003.14. Kitchen cabinets shall comply with Section 1003.12.5.					Why different requirements?
		804.5 Storage. At least 50 percent of shelf space in cabinets shall comply with Section 905.							
Storage Facilities			1	1003.14.1 Clear Floor Space. A clear floor space complying with Section 305, positioned for a parallel or forward approach, shall be provided at each storage facility					Why different requirements?
Storage Facilities			2	1003.14.2 Height. A portion of the storage area of each storage facility shall comply with at least one of the reach ranges specified in Section 308.					Why different requirements?
Storage Facilities			3	1003.14.3 Operable Parts. Operable parts on storage facilities shall comply with Section 309.		0			Why different requirements?
Accessible Communication Features		1005.1 General. Units required to have accessible communication features shall comply with Section 1005.							
Accessible Communication Features		1005.2 Unit Smoke Detection. Where provided, unit smoke detection shall include audible notification complying with NFPA 72 listed in Section 105.							
Accessible Communication Features		1005.3 Building Fire Alarm System. Where a building fire alarm system is provided, the system wiring shall be extended to a point within the unit in the vicinity of the unit smoke detection system.							
Accessible Communication Features		1005.4 Visible Notification Appliances. Visible notification appliances, where provided within the unit as part of the unit smoke detection system or the building fire alarm system, shall comply with Section 1005.4.							
Accessible Communication Features		1005.4.1 Appliance. Visible notification appliances shall comply with Section 702.							
Accessible Communication Features		1005.4.2 Activation. All visible notification appliances provided within the unit for smoke detection notification shall be activated upon smoke detection. All visible notification appliances provided within the unit for building fire alarm notification shall be activated upon activation of the building fire alarm in the portion of the building containing the unit.							

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading

				809.5.2.2 Activation. All visible alarm appliances provided within the residential dwelling unit for smoke detection notification shall be activated upon smoke detection					
Accessible Communication Features	1005.4.3 Interconnection. The same visible notification appliances shall be permitted to provide notification of unit smoke detection and building fire alarm activation.			809.5.3 Interconnection. The same visible alarm appliances shall be permitted to provide notification of residential dwelling unit smoke detection and building fire alarm activation.					
Accessible Communication Features	1005.4.4 Prohibited Use. Visible notification appliances used to indicate unit smoke detection or building fire alarm activation shall not be used for any other purpose within the unit.			809.5.4 Prohibited Use. Visible alarm appliances used to indicate residential dwelling unit smoke detection or building fire alarm activation shall not be used for any other purpose within the residential dwelling unit.					
Accessible Communication Features	1005.5 Unit Primary Entrance. Communication features shall be provided at the unit primary entrance complying with Section 1005.			809.5.5 Residential Dwelling Unit Primary Entrance. Communication features shall be provided at the residential dwelling unit primary entrance complying with 809.5.5.					
Accessible Communication Features	1005.5.1 Notification. A hard-wired electric doorbell shall be provided. A button or switch shall be provided on the public side of the unit primary entrance. Activation of the button or switch shall initiate an audible tone within the unit.			809.5.5.1 Notification. A hard-wired electric doorbell shall be provided. A button or switch shall be provided outside the residential dwelling unit primary entrance. Activation of the button or switch shall initiate an audible tone and visible signal within the residential dwelling unit. Where visible doorbell signals are located in sleeping areas, they shall have controls to deactivate the signal.					
Accessible Communication Features	1005.5.2 Identification. A means for visually identifying a visitor without opening the unit entry door shall be provided. Peepholes, where used, shall provide a minimum 180-degree range of view.			809.5.5.2 Identification. A means for visually identifying a visitor without opening the residential dwelling unit entry door shall be provided and shall allow for a minimum 180 degree range of view.					
Accessible Communication Features	1005.6 Site, Building, or Floor Entrance. Where a system permitting voice communication between a visitor and the occupant of the unit is provided at a location other than the unit entry door, the system shall comply with Section 1005.			809.5.6 Site, Building, or Floor Entrance. Where a system, including a closed-circuit system, permitting voice communication between a visitor and the occupant of the residential dwelling unit is provided, the system shall comply with 708.4.					
Accessible Communication Features	1005.6.1 Public or Common-Use Interface. The public or common-use system interface shall include the capability of supporting voice and TTY communication with the unit interface.								
Accessible Communication Features	1005.6.2 Unit Interface. The unit system interface shall include a telephone jack capable of supporting voice and TTY communication with the public or common-use system interface.								
Accessible Communication Features	1005.7 Closed-Circuit Communication Systems. Where a closed-circuit communication system is provided, the public or common-use system interface shall comply with Section 1005. 1, and the unit system interface in units required to have accessible communication features shall comply with Section 1005.								

Dark Shading=Same
 Light Shading=Referenced text
 Bold #'s are req. per heading

Dark Shading=Same
Light Shading=Referenced text
Bold #'s are req. per heading