



JENSEN HUGHES

Advancing the Science of Safety

## Quantifying the Impact of Portable Fire Extinguisher Agents on Cultural Resource Materials: Fire and Non-Fire Exposure Tests

Matthew E. Benfer, Joseph L. Scheffey, and Eric W. Forssell  
(JENSEN HUGHES)

Emily Williams (Colonial Williamsburg)

SupDet 2016 – San Antonio, TX  
March 1, 2016

# OBJECTIVES

- Quantify impact of discharging agent on materials
- Provide data to NFPA 909 and 914 for extinguisher selection
- Evaluate effectiveness of cleaning methods
- Establish cost-effective and repeatable test protocol for future use



# OBJECTIVES

## Extinguisher Selection Matrix

Materials	Extinguishing Agent				
	ABC Dry Chem.	CO <sub>2</sub>	FE-36	Halotron I	Water
<b>Architecture</b> (brick, concrete, tile, plaster)	<p><b>For each combination:</b></p> <ul style="list-style-type: none"><li>• List effects of agents<ul style="list-style-type: none"><li>• Cleaning methods</li></ul></li><li>• Recommendation of agent for use with material?</li></ul>				
<b>Ethnographic Collections</b> (bark, baskets, dolls, tools)					
<b>Glass and Ceramics</b> (China, crystal, earthenware, pottery)					
<b>Leather and Related Materials</b>					
<b>Metals</b> (Brass, bronze, iron, silver)					
<b>Paper</b>					
...					



# RESEARCH TEAM

This project was carried out under a Institute of Museums and Library Services National Leadership Grant:



- CWF –material selection, quantify agent effects, evaluate cleaning methods
- Jensen Hughes – fire and non-fire testing
- FPRF – facilitator for technical review and dissemination
- Amerex – in-kind contribution of extinguishers



# TECHNICAL OVERSIGHT PANEL

- Steve Carter, Orr Protection Systems
- Laura E. Doyle, U.S. General Services Administration
- David Frable, U.S. General Services Administration
- Deborah L. Freeland, Arthur J. Gallagher & Co.
- Cindy Greczek, Colonial Williamsburg Foundation
- Gregory E. Harrington, NFPA
- Michael Kilby, Smithsonian Institution
- Nancy Lev-Alexander, U.S. Library of Congress
- Jacob Ratliff, NFPA
- Joseph A. Senecal, Kidde-Fenwal
- Craig Voelkert, Amerex Corporation
- Rob Waller, Protection Heritage Group



Smithsonian



# BACKGROUND

## Phase I FPRF study conducted by Jensen Hughes in 2010:

- Detailed review of portable extinguishers
- Identification of material characteristics for agents and collection materials
- Comprehensive literature review of the effects of extinguishers and decomposition products
- Characterized fire scenarios and fire loss review for museums, libraries, and other heritage buildings
- Developed preliminary test plan for non-fire exposure tests, fire exposure tests, and physical impact tests



# APPROACH

- Non-fire (neat) exposure tests
  - Chemical, physical, and thermal effects from extinguisher agents
- Fire exposure tests
  - Chemical, physical, and thermal effects from extinguisher agents
  - Decomposition product effects
  - Limited direct smoke/thermal effects from fire
  - Low fire size to room volume ratio



# TEST SETUP

- Test Enclosures: nominally 10 m (33 ft) by 10 m (33ft) by 3 m (9.8ft)
- Three target arrays:
  - Direct
  - Indirect, mounted on wall
  - Indirect, mounted on a stand
- Non-fire tests @ Jensen Hughes Lab
- Fire tests @ Naval Research Lab





# EXTINGUISHERS

- Collection areas are typically light (low) hazard
- Minimum UL 711, 2A rating required for light hazard
- Five extinguishers/scenarios selected (all have 2A ratings):
  - ABC Dry Chemical [Amerex B456];
  - Water Mist [Amerex B272NM];
  - Halotron [Amerex 398];
  - FE-36 [Ansul Cleanguard FE13]
  - ABC Dry Chemical and Water Mist





# NON-FIRE EXPOSURE TESTS



# SCOPING TEST RESULTS

Conducted to determine:

- Separation distance between extinguisher and direct array:
  - Between 3.0 m (10 ft) and 4.9 m (16 ft)
- Separation distance between direct and indirect arrays
  - 1.5 m (5 ft)
- Lateral offset between direct and indirect arrays
  - 1.8 m (6 ft)



# INSTRUMENTATION

- Agent deposition on materials (scales: 0.1 g and 0.001 g resolution)
- Temperature/relative humidity measurements
- Temperature in test enclosure
  - Thermocouples at 0.3 to 2.7 m (1 – 9 ft) above floor; at 0.6 m (2 ft) increments
- Temperature at center of direct array
- Video cameras
- Infrared camera – capture spray impact pattern



# PROCEDURES


- 1) Weigh and mount all samples on arrays in examination room
- 2) Install arrays in test enclosure
- 3) Discharge extinguisher(s) at direct array until empty
- 4) Remove sample arrays 5 minutes after end of discharge (soak period)
- 5) Photograph, document, and weigh test samples
- 6) Ventilate and clean test enclosure



# RESULTS

## ○ Halotron



- Narrow stream of gas with some liquid agent
- Infrared useful for qualitative assessment of impact area



# RESULTS

## ○ FE-36

- Narrow stream of liquid
- Liquid impact area identifiable from frost on samples
- No IR camera for test





# RESULTS

## ○ Water Mist

- Wide stream/cone of mist
- Agent obscured samples for IR camera
- Large wet area on floor


## ○ ABC Dry Chemical

- Medium stream of agent
- Agent obscured samples for IR camera



# RESULTS

- Direct Array Temperatures
  - Clean agents: lowest temperatures (FE-36:  $-41^{\circ}\text{C}$ ; Halotron:  $-23^{\circ}\text{C}$ )
  - ABC Dry Chemical & Water Mist: negligible temperature change
  
- Extinguisher Agent Deposition
  - Slight deposition for most materials
  - Direct array samples had largest agent deposits, some fur samples gained up to 2.0g
  - Difficulties with mass measurement:
    - Some samples fell and broke,
    - Velcro adhesive removed bits from the backs of samples



# FIRE EXPOSURE TESTS



# SCOPING TEST RESULTS

## ○ Fire Size:

- UL 711, 1A crib too severe for unprotected person
- UL 711, 1A crib extinguished by all extinguishers
- UL 1715 wood crib selected
- Ignition pan parameters established (heptane)

## ○ Separation distance between wood crib and direct array set at 0.66 m (26 in)

## ○ Same separation distances between direct and indirect arrays as non-fire exposure tests

## ○ Initial attack distance was 1.8 m (6.0 ft)

UL 711, 1A



UL 1715



# TEST SETUP AND INSTRUMENTATION

- Instrumentation same as non-fire tests
- Corrosion monitoring system
  - Copper and silver sacrificial circuits
  - Resistance measured before and after test to determine metal loss (in Angstroms, Å)



# PROCEDURES



# RESULTS

Test Number	Agent	Extinguishing Time (sec)	Extinguisher Discharge Time (sec)	Agent Discharged (kg (lb))
1B	ABC Dry Chem	3	33	4.5 (9.9)
2B	Water Mist	6	88	9.0 (19.8)
3B	Halotron	3	13	7.0 (15.5)
4B	FE-36	4	14	6.0 (13.2)
5B	ABC Dry Chem & Water Mist	1	ABC: 34 Water: 83	ABC: 4.5 (9.9) Water: 8.8 (19.4)
6B	ABC Dry Chem & Water Mist	1	ABC: 32 Water: 93	ABC: 4.5 (9.9) Water: 9.0 (19.8)



# RESULTS – TEMPERATURE

- Direct sample array temperatures were notably higher than for non-fire tests

Test No.	Agent	Direct Sample Array Temp. At End of Discharge (°C)	Non-Fire Test Minimum Direct Sample Array Temp. During Discharge (°C)
1B	ABC Dry Chem.	55	20
2B	Water Mist	31	14
3B	Halotron	-3	-23
4B	FE-36	18	-41
5B	ABC & Water Mist	58	15
6B	ABC & Water Mist	61	15





# RESULTS

## Extinguisher Agent Deposition

*Nominally the same as non-fire tests*

- Slight deposition for most materials
- Direct array samples had largest agent deposits, some fur samples gained up to 2.0g
- Difficulties with mass measurement:
  - Some samples fell and broke,
  - Velcro adhesive removed bits from the backs of samples



# SAMPLES- OBSERVATIONS



Water Mist



Halotron



FE-36



# SAMPLES- OBSERVATIONS




ABC Dry Chemical

# SAMPLES- OBSERVATION - Halotron




Acrylic Paint



# CLEANING

## 4 methods for cleaning chosen:

- Swabbing with Deionized water
- Soot eraser
- Brushing
- Vacuuming




# CLEANING

Swabbing

Brushing

Soot eraser

Vacuuming



# SUMMARY

- A reproducible test method was established for fire and non-fire tests
- Wide range of materials and extinguisher agents evaluated
- Conservator assessment/observation of materials is complete; analysis is ongoing
- Final project report in October 2016



# ACKNOWLEDGEMENTS

This work was carried out under IMLS-NLG Grant MG-30-13-0083-13.

The authors would like to thank the NFPA Research Foundation personnel and project Technical Panel for their assistance in guiding the test planning and advising the test group.

The authors would also like to thank Amerex for their generous donation of extinguishers used in testing.





# QUESTIONS?

## Contact

Matthew E. Benfer  
+1 410-737-8677  
mbenfer@jensenhughes.com

Emily Williams  
+1 757-220-7079  
ewilliams@cwf.org

